



ACCESS  
ANALYTICAL, INC.

15 Thames Valley Rd.  
Irmo, SC 29063

Phone: 803-781-4243 / Fax: 803-781-4303 /  
Web: www.axs-inc.com

2404M73

CHAIN OF CUSTODY RECORD

FOR

ASBESTOS OR LEAD BASED PAINT SAMPLES

CLIENT:	City of Florence	PHONE:	843-713-7645
ADDRESS:	901 Cannon Flo SC	EMAIL:	oshabazz@cityofflorence.com
CONTACT:	Andrea N. Shabazz	PROJECT NAME:	901 Cannon
SAMPLE DATE:	04/18/2024	SAMPLED BY:	Andrea N. Shabazz
		STATE COLLECTED IN:	SC

TEM CONFIRMATION OF NEGATIVE NOB SAMPLES?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	POSTIVE STOP IF ONE LAYER HAS ASBESTOS?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
---	---	---	---

SAMPLE ID	SAMPLE DESCRIPTION	DATE DUE	***CIRCLE ANALYSIS REQUESTED***	LAB ID (LAB USE ONLY)
In I 1	Interior wall ins	04/18/24	ASBESTOS via PLM / LEAD in PAINT	
Ext 2	Exterior wall mat	04/18/24	ASBESTOS via PLM / LEAD in PAINT	
R 1 A	Roof Material	04/18/24	ASBESTOS via PLM / LEAD in PAINT	
			ASBESTOS via PLM / LEAD in PAINT	
			ASBESTOS via PLM / LEAD in PAINT	
			ASBESTOS via PLM / LEAD in PAINT	
			ASBESTOS via PLM / LEAD in PAINT	
			ASBESTOS via PLM / LEAD in PAINT	
			ASBESTOS via PLM / LEAD in PAINT	
			ASBESTOS via PLM / LEAD in PAINT	
			ASBESTOS via PLM / LEAD in PAINT	
			ASBESTOS via PLM / LEAD in PAINT	
			ASBESTOS via PLM / LEAD in PAINT	
			ASBESTOS via PLM / LEAD in PAINT	
			ASBESTOS via PLM / LEAD in PAINT	
			ASBESTOS via PLM / LEAD in PAINT	
			ASBESTOS via PLM / LEAD in PAINT	

RELINQUISHED BY: <i>Andrea N. Shabazz</i>	RECEIVED BY: <i>Amart</i>	DATE/TIME: 4-18-24 @ 12:28
RELINQUISHED BY: <i>Amart</i>	RECEIVED BY: <i>[Signature]</i>	DATE/TIME: 4/18 5:27 PM
RELINQUISHED BY: <i>[Signature]</i>	RECEIVED BY: <i>[Signature]</i>	DATE/TIME: 4/18 9:00

**Bulk Sample Summary Report**

Report Date: 19-Apr-24

Client Name: <b>City of Florence</b>	AES Job Number: <b>2404M73</b>
Project Name: <b>901 Cannon</b>	Project Number:

Client ID	AES ID	Location	Asbestos Mineral Percentage						Comments
			CH	AM	CR	AN	TR	AC	
INI1 Layer: 1	2404M73 -001A	SEE COC	ND	ND	ND	ND	ND	ND	Tape
INI1 Layer: 2	2404M73 -001A	SEE COC	ND	ND	ND	ND	ND	ND	Black mastic
INI1 Layer: 3	2404M73 -001A	SEE COC	ND	ND	ND	ND	ND	ND	Insulation
EXT2 Layer: 1	2404M73 -002A	SEE COC	ND	ND	ND	ND	ND	ND	Compound. Paint included as binder
R1A Layer: 1	2404M73 -003A	SEE COC	ND	ND	ND	ND	ND	ND	Felt

Note: CH=chrysotile, AM=amosite, CR=crocidolite, AC=actinolite, TR=tremolite, AN=anthophyllite

For comments on the samples, see the individual analysis sheets.

ND = None Detected

AES, Inc. is accredited by NIST's National Voluntary Laboratory Accreditation Program (NVLAP) for Polarized Light Microscopy (PLM) analysis, Lab Code 102082-0. All analyses performed in accordance with EPA "Interim Method for the Determination of Asbestos in Bulk Insulation Samples" (EPA 600/M4-82-020), 1982 as found in 40 CFR, Part 763, Appendix E to Subpart E and "Method for the Determination of Asbestos in Bulk Building Materials" (EPA/600/R-93/116), 1993.


These test results apply only to those samples actually tested, as submitted by the client. All percentages are reported by visually estimated volume.

PLM is not consistently reliable in detecting small concentrations of asbestos in floor tiles and similar nonfriable materials, quantitative TEM is currently the only method that can be used to determine conclusive asbestos content. Interpretation and use of test results are the client's responsibility.


Laboratory liability is limited to the cost of analysis. This report must not be used to claim, and does not imply product certification, approval, or endorsement by NVLAP or any agency of the Federal Government.

This report must not be reproduced except in full without written approval of Analytical Environmental Services, Inc

Microanalyst:

  
Elena Ivanova

QC Analyst:

  
Yelena Khanina